



Building/Energy Code Checklist Subject-to-Field-Inspection Permits (R-2/R-3)

Property Address: _____

Project #: _____ Permit #: _____

I understand that items indicated below are required by code and will have to be addressed before the Building Inspector will approve the final inspection. I understand that if I am uncertain as to specific code requirements, I may contact my inspector for clarification. Otherwise, I accept responsibility for code compliance and for making changes as required by my inspector to meet code requirements.

I also understand and acknowledge that no review will take place under this permit to verify existing uses and occupancies. I accept full responsibility for the accuracy of the information regarding the existing legally established uses, and understand that in no case does this permit serve to establish a new use or occupancy, nor to change an existing use or occupancy.

I understand that this document is to be kept with my issued permit and is part of the approved permit documents. I further understand and acknowledge that this permit may be revoked should I exceed the scope of work authorized by this permit or should I fail to comply with the requirements therein.

(Signature) _____

- _____ 1. *Separation between dwelling and garage/carport:*
 - _____ a. No separation required if entirely open on 2 or more sides and no enclosed uses. (Decks non-rated walls and openable windows are okay).
 - _____ b. Minimum 1/2" GWB on garage/carport side required for all garages/carports not covered by 1a above.
 - _____ c. 1-hour firewall required if less than 5 feet from property line (no openings allowed less than 3' from property line, 25% maximum openings between 3' and 5' to property line). Overhangs must be a minimum 2' from property line, except steel gutter allowed closer and 1/2" GWP sheathing required on underside when 5' or less from property line.
- _____ 2. *Egress windows: Required for 1 window/bedroom or sleeping area (below 4th floor) and 1 window/basement.*
 - _____ a. Min. net clear area = 5.7* sq. ft., (min. 3'0" x 4'6" if double hung or 4'0" x 3'6" window if slider). * 5.0 sq. ft. if sill height is within 44" of grade (above or below).
 - _____ b. Min. net clear opening width = 20"; min. net clear opening height = 24".
 - _____ c. Max. sill height = 44" (one permanently installed step okay for existing basement).
- _____ 3. *Required glazing for habitable rooms:*
 - _____ a. Min. glazed exterior opening area = 8% of floor area.
 - _____ b. Glazed openings not required where permanently installed artificial light is provided.
 - _____ c. OK if openings are below decks & roofed porches w/min. ceiling ht. of 7 ft. (long side 65% open).
- _____ 4. *Mechanical/Ventilation – required for habitable rooms of additions and alterations more than 500 sq. ft. or that include a kitchen, bathroom and other areas where cooking odor or excess water vapor will be produced.*
 - _____ a. Min. 50 CFM for bathroom and laundry; min. 100 CFM for kitchen.
 - _____ b. Min. air intake openings = 4 sq. in. per room.
 - _____ c. Whole house fan: SRC Ch.15
- _____ 5. *Smoke detector required inside and outside of sleeping areas and all floors. May retrofit with battery-operated or direct wired smoke detectors.*
- _____ 6. *Stair requirements (applies to all R-3 stairs and R-2 private stairways):*
 - _____ a. Min. width = 36"
 - _____ b. Max. height/rise = 7 3/4"; min. tread run = 10"
 - _____ c. Min. headroom = 6'8"
 - _____ d. Handrail 34"-38" above tread nosing (return ends)
 - _____ e. Handrail grasp dimension: min. 1 1/4", max. 2"
 - _____ f. Winding stairs:
 - Min. tread run at narrowest point = 6"
 - Min. tread run 12" from narrowest point = 10"
 - _____ g. Spiral stairs:
 - Min. clear walking area width = 26"
 - Min. tread run 12" from narrowest point = 7 1/2"/max. riser height = 9 1/2"

- _____ 7. *Ceiling height in additions and alterations:*
- _____ a. Min. 7'0": for new construction or additions
- _____ b. Min. 6'4": if building was in existence prior to 10/17/79 (see DR 23-2008 for specifics).
- _____ c. Rooms with sloped ceilings require minimum ceiling height in ½ of the area. (Portions of the room with ceiling height less than 5 ft. do not count in total area).
- _____ 8. *Energy requirements (Prescriptive approach – Table 6-1, Option II only) for alterations:*
- _____ a. Min. ceiling insulation = R-49 or R-38 advanced (full depth to eaves), (R-38 at single rafter ceilings)
- _____ b. Min. wall insulation = R-21 cavity insulation + R-10 insulated headers (Note: Framing must be wood. Metal not allowed under prescriptive approach)
- _____ c. Min. floor insulation above unheated space = R-30
- _____ d. Min. slab on grade perimeter insulation = R-10
- _____ e. Max. glazing U-factor (see CAM #303A and 403)
U = 0.32 for vertical (windows and doors); U = 0.50 for overhead (skylights)
- _____ f. Max. door U-factor = 0.20
- _____ g. Max. glazed area = 25% of floor area
Note: Count rough opening area for all glazing in house and entire heated floor area.
- _____ h. If increasing rough openings for glazed areas (only allowed for up to, but not exceeding, 25% of the floor area), you must compensate with one or a combination of the following:
- 65 x _____ sq. ft. of total net increase in rough area openings = _____ sq. ft. of R-49/R-38 insulation in ceiling/single-rafter or R-30 insulation for crawl space or unheated floor.
 - 1 x _____ sq. ft. of total net increase in rough area openings = _____ sq. ft. of existing windows to be replaced with U = 0.32
- _____ i. Other: add notes for Energy certificate (105.4), duct leakage testing if furnace replaced (101.3.2.6)
- _____ 9. *Energy requirements (Prescriptive approach) For additions only: Heat source: _____*
- _____ a. Provide calculations if using area-weighted averaging for glazing (see CAM 303)
- _____ b. Glazing percentage proposed _____%; required Prescriptive path _____:
- | | |
|------------------------------|------------------------------------|
| Windows U-factor: _____ | Wall insulation above grade: _____ |
| Skylight U-factor: _____ | Wall insulation below grade: _____ |
| Doors U-factor: _____ | Interior: _____ |
| Ceiling insulation: _____ | Exterior: _____ |
| Single-rafter ceiling: _____ | Insulation for _____ |
| Floor insulation: _____ | Slab on grade: _____ |
- Note that 2 x 12 framing is required for single rafter ceilings with R-30 fiberglass batts. R-21 wall insulation requires 2 x 6 construction for fiberglass batts. Framing must be wood. Metal not allowed under prescriptive approach.
- _____ c. Chapter 9, additional requirements: specify option(s) selected (can use Option 6 if < 750 sq.ft.)
- _____ d. Other: add notes for Energy certificate (105.4), duct leakage testing if furnace replaced (101.3.2.6) building air leakage testing if addition > 750 sq.ft.(502.4.5)
- IF ADDING NEW HEATING EQUIPMENT CAPACITY, BRING A COPY OF THIS FORM WHEN APPLYING FOR ELECTRICAL OR FURNACE PERMIT.**
- _____ e. Heat source for the addition: _____ new; _____ extension of existing system; _____ unheated.
- _____ f. If new heat, maximum capacity allowed: 12 BTUH/sf or 3.5 WATTS/sf X _____sf addition = _____ BTUH, or _____ WATTS.
- _____ g. If extending existing system, Equipment Sizing Form must be provided with Electrical/Furnace Permit application.
- _____ 10. Foundation location: **Property corners** must be accurately determined and indicated on site for foundation inspection. A survey **may** be required. Fence locations will not be accepted as establishing property corners.
- _____ 11. Other requirements:
- _____ a. *Guardrails:* min. 36" ht. max. 4" spacing between intermediate members (42" min. ht. for R-2 exterior).
- _____ b. *Footings:* bottom min. 12" below grade, top of foundation wall min. 6" above grade.
- _____ c. *Concrete slabs on grade:* 3 ½" min. thicknesses.
- _____ d. *Pier blocks:* min. 12" x 12" size; resting on concrete pad min. 12" below grade.
- _____ e. *Foundation walls:* Provide one (1) #4 rebar top and bottom and at all windows/door openings. Limit 4' max. backfill, see CAM 303A.
- _____ f. *Foundation anchor bolts:* min. ½" x 10", 6 ft. on center max. with two (2) bolts per piece of plate and at least one (1) bolt within 12" at end of each piece (required for new construction).
- _____ 12. **IF THIS LINE IS CHECKED, YOU MUST CONTACT YOUR INSPECTOR PRIOR TO BEGINNING THE CONSTRUCTION.**