

Name \_\_\_\_\_

Confidence Test Report

Address \_\_\_\_\_

206-386-1448 Confidence Testing Officer

Phone \_\_\_\_\_

206-615-1068 (fax)

Here \_\_\_\_\_

206-233-7219 Red Tag Hotline

# SEQUENCE TEST

(One System per Report)

Certification Given

RED

YELLOW

WHITE

CONFIDENCE TEST

REPAIRS

Occupancy Address: \_\_\_\_\_

Occupancy Name: \_\_\_\_\_

Responsible Person  
First & Last Name: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Responsible Person  
Address, City, State, Zip: \_\_\_\_\_

Responsible Party  
E-Mail Address: \_\_\_\_\_

Date of Inspection: \_\_\_\_\_

Inspection  
Frequency/Type: **Annual**

Testers Name  
(Please Print): \_\_\_\_\_

SFD Certification  
Number: SCP-\_\_\_\_\_

Central station monitoring? Yes  No

Monitoring

Monitoring Required? Yes  No

Company Name: \_\_\_\_\_

**SEATTLE FIRE CODE VIOLATIONS FOUND:** (If additional room is needed, please add a separate sheet)

**CORRECTIONS MADE:** Date Corrected: \_\_\_\_\_ Corrected By: \_\_\_\_\_

(If additional room is needed, please add a separate sheet) SFD Certification Number: SCP - \_\_\_\_\_

This certifies that this fire and life safety system has been properly inspected for reliability to cover the items listed in this report and is consistent with Seattle Fire Department Fire Code standards, and that discrepancies are noted and have been reported to the building Owner/Manager for corrective action.

Signature of Tester: \_\_\_\_\_ Phone # \_\_\_\_\_

Building Representative (signature) \_\_\_\_\_

The below checklist shall be inspected and tested. This list does not constitute all of the required inspecting and testing of the fire and life safety system. Refer to the Seattle Fire Department Fire Code for inspecting and testing requirements.

### Normal Power Operation

1. Was alarm initiated from a random device?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
2. Does the alarm sound on designated floors?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
3. Is audibility satisfactory?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
4. Do the elevators return to recall floor?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
5. Do the fire dampers operate properly?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
6. Did building HVAC (air conditioning) shut off with fire alarm activation?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
7. Did shaft pressurization fans operate?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
8. Did the stairway doors unlock, but not unlatch?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
9. Do elevators operate properly from fire control inside each car?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
10. Does fire pump operate properly?	Yes <input type="checkbox"/>	No <input type="checkbox"/>

### Emergency Power Operation

11. Was power shut off at main breaker?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
12. Did emergency generator operate within 15 seconds?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
13. Does fire alarm operate on a generator?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
14. Do elevators operate on generator?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
15. Can emergency power be manually assigned to any elevator?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
16. How much time does it take to assign emergency power automatically from one elevator car to another?	_____	Seconds
17. Do the elevators return to recall floor?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
18. Do elevators operate properly from fire control inside each car?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
19. Fire dampers continue to operate?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
20. Does fire pump operate?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
21. Did building HVAC (air conditioning) shut off with fire alarm activation?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
22. Did shaft pressurization fans operate?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
23. Did the stairway doors unlock, but not unlatch?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
24. Does fire pump operate properly?	Yes <input type="checkbox"/>	No <input type="checkbox"/>